

**American Standard, Inc.
The Trane Company
Tyler, TX 75711-9010**

Assembled in USA

TWE036P130B0	3472DC42V	1/3	2.20	200 - 230	1 Ph 60 Hz
MODEL NO.	SERIAL NO.	MOTOR H.P.	F.L. AMPS	VOLTS	
	FACTORY INSTALLED			MAY BE FIELD INSTALLED	

**ELECTRIC HEATER - 208 OR
240V, 60Hz, 1PH OR 3PH**

REFRIGERANT 22 ONLY DESIGN PRESSURE 300 PSI

**UNLESS INDICATED "NA" ANY ONE OF THE FOLLOWING HEATERS MAY BE
INSTALLED IN THIS UNIT. INSTALLER MUST MARK ONE APPROPRIATE BLOCK
IN COLUMN A**

MFR DATE: **11/2003**

A	TRANE HEATER MODEL	SUPPLY		HEATER KW AMPS	MIN BRANCH CIRCUIT AMPACITY	MAXIMUM OVERCURRENT DEVICE	MINIMUM HEATING BLOWER SPEED	
		VOLTS	PHASE				WITHOUT HEAT PUMP	WITH HEAT PUMP
	NONE	USE ACC PLATE BAY99X123			2.8	15		
		208		3.60 17.3	24	25	LOW	LOW

American Standard, Inc.
The Trane Company
Tyler, TX 75711-9010

Assembled in USA

TWE036P130B0 3472DC42V 1/3 2.20 200-230

MODEL NO. SERIAL NO. MOTOR & P. F.L. AMPERES VOLTS
FACTORY INSTALLED MAY BE FIELD INSTALLED

ELECTRIC HEATER - 208 OR 240V, 50Hz, 1PH OR 3PH
REFRIGERANT 22 ONLY DESIGN PRESSURE 300 PSI
UNLESS INDICATED "NA" ANY ONE OF THE FOLLOWING HEATERS MAY BE INSTALLED IN THIS UNIT. INSTALLER MUST MARK ONE APPROPRIATE BLOCK IN COLUMN A
REF. DATE: 11/2003

A. TRANE HEATER MODEL	SUPPLY VOLTS	POWER KW	HEATER KW	CIRCUIT AMPERE	MIN. BRANCH CIRCUIT AMPERITY	HEATER DISCONNECT RATING	MINIMUM HEATING BLOWER SPEED WITH HEAT PUMP	
							2.0	15
NONE								
BAYHTR1405 + + +	208	1	3.68	17.3	24	25	LOW	LOW
	240	1	4.88	20	28	33		
BAYHTR1408 + + +	208	1	5.76	27.7	37	43	LOW	LOW
	240	1	7.68	32	43	45		
BAYHTR1430 + + +	208	1	7.20	34.8	48	50	LOW	LOW
	240	1	9.60	43	53	60		
BAYHTR3419000	208	3	7.20	33	37	40	LOW	LOW
	240	3	9.60	34.8	43	45		
BAYHTR3416000	208	3	11.53	53.1	44	45	LOW	HI
	240	3	15.36	58.2	50	50		
CIRCUIT 1 BAYHTR1415 + + +	208	1	7.20	34.8	48	58	LOW	HI
	240	1	9.60	48	53	68		
CIRCUIT 2	208	1	4.33	20.0	25	33	LOW	HI
	240	1	5.76	24	30	33		
CIRCUIT 1 BAYHTR1418 + + +	208	1	5.76	27.7	37	40	LOW	HI
	240	1	7.68	32	43	45		
CIRCUIT 2	208	1	8.66	41.6	52	60	LOW	HI
	240	1	11.52	48	60	68		
CIRCUIT 1 BAYHTR1425 + + +	208	1	7.93	38.1	NA	NA	NA	NA
	240	1	10.56	44	NA	NA		
CIRCUIT 2	208	1	7.20	34.8	NA	NA	NA	NA
	240	1	9.60	43	NA	NA		
CIRCUIT 3	208	1	2.83	17.3	NA	NA	NA	NA
	240	1	4.80	25	NA	NA		

Note: Heater model number may have additional suffix digits
" + + + " = 000, BRK, RBR, POC, RPD

CAUTION: WHEN HEATER MODELS WITH POWER DISCONNECT ARE INSTALLED USE ONLY 240/208 VOLT SUPPLY CIRCUITS WITH 125 VOLTS TO GROUND (NOMINAL).

FOR FIELD CONNECTIONS USE COPPER CONDUCTORS ONLY.
USE ONLY APPROVED COMBINATIONS OF ELECTRIC HEATERS AND UNITS.
MINIMUM INSTALLATION CLEARANCE TO COMBUSTIBLE MATERIALS WHEN ELECTRIC HEATERS ARE INSTALLED: UNIT CABINET - 0", PLENUM - 1" AND FIRST 3' OF OUTLET DUCT - 1". MAXIMUM OUTLET AIR TEMPERATURE WITH ELECTRIC HEATERS 194 DEGREES F.

SUITABLE FOR MOBILE HOME USE
MOTOR INTERNALLY PROTECTED

NOTICE: IF AIR HANDLER IS USED WITHOUT A FACTORY FURNISHED SUPPLEMENTARY ELECTRIC HEATER, AN ACCESSORY PLATE IS REQUIRED TO COVER THE OPEN HOLE IN THE AIRFLOW SYSTEM.

WARNING: WITH HEAT PUMP INSTALLATIONS, SOME HEATERS ARE POSITION SENSITIVE. SEE "NOTES BELOW"



LISTED
SECTION OF
CENTRAL COOLING
AIR CONDITIONER 23MF

ALSO
LISTED
SECTION OF
HEAT PUMP



09070491



Heritage 12

MFR
DATE 12/2003

MOD. NO. 2A6H2036A1000AB	VOLTS	208/230
SERIAL NO. 3503Y1R4F	PH 1	HZ 60
MINIMUM CIRCUIT AMPACITY	21.0	AMPS
OVERCURRENT PROTECTIVE DEVICE	USA	CANADA
MIN FUSE / BREAKER (HACR)	30	30
MAX FUSE / BREAKER (HACR)	35	35


HCFC - 22 7 LBS. 04 OZ. OR 3.29 kg(SI)
BAYFCCV 071A REQUIRED INDOORS FOR RATED PERFORMANCE

Duration DuraBase Spine Fin Easy-Sess

AMERICAN STANDARD INC. LISTED SECTION OF HEAT PUMP

TYLER, TX 75707 ASSEMBLED IN USA  23MF OUTDOOR USE

COMPR. MOT. 16.0 RLA	208/230 V	88 LRA
O.D. MOT. 1.40 FLA	200/230 V	1/6 HP
M.E.A. NO. 250-02-E	F. ID. K60	
DESIGN PSI - HIGH 300 LOW 300		



CERTIFICATION APPLIES ONLY WHEN THE COMPLETE SYSTEM IS LISTED WITH AM